


# Multi-Jet Meters

## Operating Characteristics

Product 	Size	Typical Operating Range 100% ± 1.5%	Low Flow (Min. 95%)	Max Continuous Operating Flow	Max Operating Capacity	Pressure Loss	Max Operating Temp°	Max Operating Pressure
ID	in	gpm	gpm	gpm	gpm	psi	Temp°	psi
<a href="#">MJ-25</a>	5/8"	1/4 - 25 gpm	1/8 gpm	20 gpm	25 gpm	7.0 psi at 20 gpm	120°F	150 psi
<a href="#">MJ-28 Epoxy</a>	5/8" x 3/4"	1/4 - 28 gpm	1/8 gpm	20 gpm	28 gpm	7.0 psi at 20 gpm	120°F	150 psi
<a href="#">MJ-28 Bronze</a>	5/8" x 3/4"	1/4 - 28 gpm	1/8 gpm	20 gpm	28 gpm	7.0 psi at 20 gpm	120°F	150 psi
<a href="#">MJ-60 Epoxy</a>	1"	3 - 60 gpm	3/4 gpm	40 gpm	60 gpm	7.0 psi at 50 gpm	120°F	150 psi
<a href="#">MJ-60 Bronze</a>	1"	3 - 60 gpm	3/4 gpm	40 gpm	60 gpm	7.0 psi at 50 gpm	120°F	150 psi
<a href="#">MJ-120</a>	1 1/2"	5 - 120 gpm	1 gpm	75 gpm	120 gpm	3.3 psi at 50 gpm	120°F	150 psi
<a href="#">MJ-160</a>	2"	8 - 160 gpm	2 gpm	120 gpm	160 gpm	3.3 psi at 80 gpm	120°F	150 psi
<a href="#">MJB-35</a>	5/8" x 3/4"	1/4 - 28 gpm	1/8 gpm	20 gpm	28 gpm	7 psi at Max Capacity	120°F	150 psi
<a href="#">MJB-60</a>	1"	3 - 60 gpm	3/4 gpm	40 gpm	60 gpm	7 psi at 50 gpm	120°F	150 psi
<a href="#">MJB-120</a>	1 1/2"	5 - 120 gpm	1 gpm	75 gpm	120 gpm	12 psi at Max Capacity	120°F	150 psi
<a href="#">MJB-160</a>	2"	8 - 160 gpm	2 gpm (97 - 103%)	120 gpm	160 gpm	12 psi at Max Capacity	120°F	150 psi
<a href="#">MJH-28</a>	3/4"	1/8 - 25 gpm	1/8 gpm	20 gpm	25 gpm	2.3 psi at Max Capacity	194°F	150 psi

Meets or exceeds latest revision of AWWA C708 Performance Standards

## Physical Characteristics

Product 	Meter length		Meter Casing Spuds	Couplings (Tailpieces)	Nominal Thread Size	Weight
ID	Screw Ends	Flanged Ends	Nominal Thread Size	Length	in	
<a href="#">MJ-25</a>	7 1/2"		3/4"	2 3/8"	1/2"	3.6 lbs
<a href="#">MJ-28 Epoxy</a>	7 1/2"		1"	2 1/2"	3/4"	3.6 lbs
<a href="#">MJ-28 Bronze</a>	7 1/2"		1"	2 1/2"	3/4"	3.6 lbs
<a href="#">MJ-60 Epoxy</a>	10 3/4"		1 1/4"	2 5/8"	1"	5 lbs
<a href="#">MJ-60 Bronze</a>	10 3/4"		1 1/4"	2 5/8"	1"	5 lbs



Find out more by visiting our website at  
[www.imcmeter.com](http://www.imcmeter.com)  
[info@imcmeter.com](mailto:info@imcmeter.com)

PO Box 948  
 Claremore, OK 74018  
 TF. 888-342-2752  
 P. 918-342-2752  
 F. 918-342-5949

PO Box 1088  
 Ocala, FL 34478-1088  
 TF. 888-401-0070  
 P. 352-401-0017  
 F. 352-401-3464

<a href="#">MJ-120</a>	12 5/8" (10.8 lbs)	13" (14.8 lbs)	2"	2 7/8"	1 1/2"	
<a href="#">MJ-160</a>	15 1/4" (13.2 lbs)	10" (14.6 lbs) and 17" (19.8 lbs)	2 1/2"	3"	2"	
<a href="#">MJB-35</a>	7 1/2"		1"	2 1/2"	3/4"	4.2 lbs
<a href="#">MJB-60</a>	10 3/4"		1 1/4"	2 5/8"	1 "	5.8 lbs
<a href="#">MJB-120</a>		13 "				17.6 lbs
<a href="#">MJB-160</a>		17"				22.4 lbs
<a href="#">MJH-28</a>	7 1/2"		1"	2 1/2"	3/4"	3.6 lbs

Meets or exceeds latest revision of AWWA C708 Dimensional Standards



Find out more  
by visiting our website at  
[www.imcmeter.com](http://www.imcmeter.com)  
[info@imcmeter.com](mailto:info@imcmeter.com)

PO Box 948  
Claremore, OK 74018  
TF. 888-342-2752  
P. 918-342-2752  
F. 918-342-5949

PO Box 1088  
Ocala, FL 34478-1088  
TF. 888-401-0070  
P. 352-401-0017  
F. 352-401-3464

## Features

- 1. Main casings:** Main casings are made of a copper alloy containing not less than 85% copper such as UNS C83600 or a similar copper alloy as listed in ASTM B584 and SDWA 141.43 No Lead. The serial number is engraved on the body. The main case also shows the name of the manufacturer (IMC), the size and direction of flow.
- 2. Register housing and lids:** Register housing and lids are made of a copper alloy containing not less than 57% copper such as UNS C85700 or UNS C86200; or similar copper alloy as listed in ASTM B584 or UNS C85800, as listed in ASTM B176.
- 3. Measuring cages or chambers:** Measuring cages or chambers are made of engineering plastic, such as polyphenylene ether (PPE) per ASTM D4349, nylon (N) per ANSI/ASTM D4066, polyethylene per ASTM D1248, or polystyrene per ASTM D4549.  
  
Measuring cages or chambers have sufficient dimensional stability to retain operating clearances at working temperatures of up to 120° F (49° C) and shall not warp or deform.
- 4. Strainers:** All meters have a strainer installed in the meter. Strainer screens are rigid, snug fitting, easy to remove and have an effective straining area of at least double that of the main-case inlet.

## Warranty

### Scope of Warranty

This warranty applies exclusively to Infinity Metering C708 water meters and direct read registers purchased there when used in potable water below 120° F in accordance with Infinity Metering's published Technical Specifications and when installed in accordance with INFINITY METERING'S published installation instructions, both as in effect as of the date of Infinity Metering's shipment of the product. This guarantee applies exclusively to the original utility purchaser when product is purchased from either Infinity Metering or an Infinity Metering authorized Distributor.

### Materials and Workmanship

If used and installed as described above, Infinity Metering guarantees product covered by this guarantee to be free from defects in materials and workmanship for a period of 12 months after installation or 18 months after shipment by Infinity Metering or its authorized Distributor, whichever occurs first.

### Case Integrity

If used and installed as described above, Infinity Metering guarantees that the waterworks or low lead bronze main cases of C708 meters will retain their structural integrity for a period of 25 years from date of Infinity Metering's shipment.

### Register Functionality

If used and installed as described above, Infinity Metering guarantees that its direct read registers will function for 25 years from date of manufacture by Infinity Metering. Encoder and Pulse register warranties are specified separately.

### New Meter Accuracy

If used and installed as described above, Infinity Metering guarantees that C708 meters covered by this guarantee will meet or exceed AWWA new meter accuracy standards, per AWWA specification C708, until the first occurring event as specified below:

- 5/8" 5 years from date of Infinity Metering shipment or registered usage of 750,000 U.S. gallons;
- 3/4" 5 years from date of Infinity Metering shipment or registered usage of 750,000 U.S. gallons;
- 1" 5 years from date of Infinity Metering shipment or registered usage of 1,100,000 U.S. gallons;
- 1 1/2" 5 years from date of Infinity Metering shipment or registered usage of 1,600,000 U.S. gallons;
- 2" 5 years from date of Infinity Metering shipment or registered usage of 2,100,000 U.S. gallons.


### Repaired Meter Accuracy

If used and installed as described above, Infinity Metering further guarantees that C708 meters covered by this guarantee will meet or exceed repaired meter accuracy standards, as published in AWWA Manual M-6 Fourth Edition (1999), Chapter 5, Table 5.3, until the first occurring event as specified below:

- 5/8" 15 years from date of Infinity Metering shipment or registered usage of 2,500,000 U.S. gallons;
- 3/4" 15 years from date of Infinity Metering shipment or registered usage of 2,500,000 U.S. gallons;
- 1" 15 years from date of Infinity Metering shipment or registered usage of 3,250,000 U.S. gallons;
- 1 1/2" 15 years from date of Infinity Metering shipment or registered usage of 5,600,000 U.S. gallons;
- 2" 15 years from date of Infinity Metering shipment or registered usage of 10,400,000 U.S. gallons.

### Extended Low Flow Accuracy

If used and installed as described above, Infinity Metering further guarantees that C708 meters covered by this guarantee will



Find out more  
by visiting our website at  
[www.imcmeter.com](http://www.imcmeter.com)  
[info@imcmeter.com](mailto:info@imcmeter.com)

PO Box 948  
Claremore, OK 74018  
TF. 888-342-2752  
P. 918-342-2752  
F. 918-342-5949

PO Box 1088  
Ocala, FL 34478-1088  
TF. 888-401-0070  
P. 352-401-0017  
F. 352-401-3464

meet or exceed low flow accuracy, as specified in AWWA Specification C708, until the first occurring event as specified below:  
5/8" 5 years from date of Infinity Metering shipment or registered usage of 675,000 U.S. gallon;  
3/4" 5 years from date of Infinity Metering shipment or registered usage of 675,000 U.S. gallons;  
1" 5 years from date of Infinity Metering shipment or registered usage of 1,100,000 U.S. gallons;  
1 1/2" 5 years from date of Infinity Metering shipment or registered usage of 1,440,000 U.S. gallons;  
2" 5 years from date of Infinity Metering shipment or registered usage of 1,890,000 U.S. gallons.

### Claims

Any meter or register covered by this guarantee that fails to meet the terms of the stated guarantee will be repaired or replaced, at the option of Infinity Metering, without additional charge to the customer. The customer is responsible for removing the meter or register from service, returning it to the factory service center designated by Infinity Metering, providing a written or electronic (facsimile or e-mail) claim notice, and for freight costs to and from the service center. Customer is also responsible for reinstalling repaired or replaced product.

### Limits of Liability

This guarantee does not apply to meters or registers damaged by aggressive water conditions, foreign matter in water, vandalism, negligence, installation not in accordance with Infinity Metering's installation instructions, misapplication or other use not as described above, acts of God or other conditions beyond the control of Infinity Metering. If a meter is claimed to breach the accuracy guarantees as stated herein, the customer shall submit a certified copy of the test results at the time the meter is returned to Infinity Metering. The guarantees as to accuracy shall be void if an examination of the customer's water supply shows an unusually adverse effect on metering equipment. Any description of product, whether in writing or made orally by Infinity Metering or its agents, specifications, samples, literature, models, bulletins, drawings, diagrams, engineering sheets or similar materials used in connection with any customer's order are for the sole purpose of identifying product and shall not be construed as an express or implied guarantee.

THE FOREGOING EXPRESS GUARANTEE IS IN LIEU OF ALL OTHER GUARANTEES OR WARRANTIES WHATSOEVER, WHETHER EXPRESS, IMPLIED OR STATUTORY (EXCEPT FOR WARRANTY OF TITLE), INCLUDING BUT NOT LIMITED TO IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE. CUSTOMER'S EXCLUSIVE REMEDY AND INFINITY METERING'S AND ITS DISTRIBUTORS' SOLE LIABILITY ON ANY CLAIM, WHETHER IN TORT (INCLUDING STRICT LIABILITY), NEGLIGENCE, CONTRACT, WARRANTY OR OTHERWISE, FOR ANY METER OR REGISTER WHICH FAILS TO MEET THE TERMS OF THE GUARANTEE STATED ABOVE, SHALL BE LIMITED TO REPAIR OR REPLACEMENT AS DESCRIBED ABOVE. IN NO EVENT SHALL INFINITY METERING AND/OR ITS DISTRIBUTORS BE LIABLE FOR INCIDENTAL OR CONSEQUENTIAL DAMAGES OF ANY KIND, INCLUDING BUT NOT LIMITED TO LOSS OF PROFITS OR REVENUE, LOSS OF USE, COST OF CAPITAL, COST OF SUBSTITUTE EQUIPMENT, FACILITIES OR SERVICES, DOWNTIME COSTS, DELAYS AND CLAIMS OF CUSTOMERS OF THE CUSTOMER OR OTHER THIRD PARTIES.



Find out more  
by visiting our website at  
[www.imcmeter.com](http://www.imcmeter.com)  
[info@imcmeter.com](mailto:info@imcmeter.com)

PO Box 948  
Claremore, OK 74018  
TF. 888-342-2752  
P. 918-342-2752  
F. 918-342-5949

PO Box 1088  
Ocala, FL 34478-1088  
TF. 888-401-0070  
P. 352-401-0017  
F. 352-401-3464